


TESTCONSULT
TESTING AND CONSULTING SERVICES

TEST CERTIFICATE

Pedestrian Barrier



Client: A- FAX Ltd
Shady Lane
Halifax
HX3 6RL

Ref No: S2779
Job No: A4722
Date Tested: 10/10/2005
Date Reported: 20/10/2005

Site: Testconsult Ltd, Ruby House, 40A Hardwick Grange, Woolston, Warrington, Cheshire, WA1 4RF
Barrier System: Pedestrian Barrier
Test Specification: BS 6399 Part 1 : 1996 Table 4 (xi) Minimum horizontal loads for barriers.
Test Engineer: Mark Mairs / Lee Waterhouse

Test No.	Test Specification	Load (KN)	Max Deflection (mm)	Remarks (Pass/Fail)
1	Horizontal uniformly Distributed line load (kN/m)	1.5	56	Conforms to BS 6399 Part 1 : 1996 Table 4 (xi) Minimum horizontal loads for barriers. PASS
2	A uniformly distributed load applied to the infill (kN/m ²)	1.5	31	Conforms to BS 6399 Part 1 : 1996 Table 4 (xi) Minimum horizontal loads for barriers. PASS
3	A point load applied to part of the infill (kN)	1.5	93	Conforms to BS 6399 Part 1 : 1996 Table 4 (xi) Minimum horizontal loads for barriers. PASS

Lee Waterhouse
Instrumentation Engineer
TESTCONSULT LIMITED